



Specializing in Fire, Building, and Life Safety

Corporate Office

2420 Alft Lane
Elgin, IL 60124
P: 847.697.1300
F: 847.697.1310
www.firesafetyfsci.com

Regional Office

23650 Woodward Avenue
Suite 200
Pleasant Ridge, MI 48069
P: 248.545.3330
F: 248.545.3376

LIFE SAFETY CODE SUBMITTALS

Information Required for Submittal to be Reviewed by FSCI

See NFPA 101 for a complete submittal list.

- ☐ Complete plans showing the job name and complete address, and shall include the design professional in charge name, address and phone number.
- ☐ Plans must be signed and sealed by the design professional in charge of the project and include all architectural, electrical, plumbing, mechanical, accessibility, etc. drawings and material specifications.
- ☐ Plans must be to scale, fully dimensioned to determine building area and height, and clearly show work to be done including a detailed scope of work.
- ☐ Provide a scaled site plan clearly showing any existing structures, all new construction, distance from lot lines, street grades, proposed finish grades, location of underground mains, fire hydrant locations, building fire department connection location and any fire department access lanes.
- ☐ Description of building use or occupancy for all areas of the building.
- ☐ Description of design approach for mixed use buildings.
- ☐ Proposed type of construction including testing/listing agency details for all fire rated construction.
- ☐ Hazard of content classification and any proposed special storage arrangements.
- ☐ Complete exit details to fully evaluate the means of egress including, occupant loads, means of egress arrangement, corridors, doors, stairs, exit signage, emergency lighting, emergency power supply, etc.

- ☐ Special occupancy information including; assembly, high rise, mezzanine, atrium, covered mall, underground building, etc.
- ☐ Details for all fire protection systems proposed including fire sprinklers, fire alarm, standpipes, fire pumps, and other extinguishing systems.