



Specializing in Fire, Building, and Life Safety

Corporate Office

2420 Alft Lane
Elgin, IL 60124
P: 847.697.1300
F: 847.697.1310
www.firesafetyfsci.com

Regional Office

23650 Woodward Avenue
Suite 200
Pleasant Ridge, MI 48069
P: 248.545.3330
F: 248.545.3376

KITCHEN HOOD WET CHEMICAL SYSTEM SUBMITTALS

Information Required for Submittal to be Reviewed by FSCI

See NFPA 17A for a complete submittal list.

- ☐ Plans must include exact hood, duct, piping, and appliance dimensions. A scaled front elevation and isometric view shall be included.
- ☐ Plans must show job name and complete address.
- ☐ Catalog cut sheets must be provided for all nozzles and equipment to be used.
- ☐ The tank size and flow point count must be noted on the plans.
- ☐ All plans must have the contractors name, address, and phone number.
- ☐ A plan view of the kitchen must show the hood, tank, and pull station locations.
- ☐ The plans must clearly show the type of nozzles to be used and show the mounting height, and aiming point for each.