



Specializing in Fire, Building, and Life Safety

Corporate Office

2420 Alft Lane
Elgin, IL 60124
P: 847.697.1300
F: 847.697.1310
www.firesafetyfsci.com

Regional Office

23650 Woodward Avenue
Suite 200
Pleasant Ridge, MI 48069
P: 248.545.3330
F: 248.545.3376

ALTERNATIVE EXTINGUISHING SYSTEM SUBMITTALS

Information Required for Submittal to be Reviewed by FSCI

See applicable NFPA standard for a complete submittal list.

- ☐ Plans must be to scale and clearly show all work to be done.
- ☐ Plans must show the job name and complete address.
- ☐ A key plan shall be provided showing the area of work in the building.
- ☐ Complete catalog cut sheets shall be provided for all equipment to be used.
- ☐ The scope of work shall include a description of hazard being protected and type/manufacture of agent being used.
- ☐ Calculations for required agent quantity and discharge time shall be provided.
- ☐ Installation manual for pre-engineered systems.
- ☐ All alarm portions of the system shall comply with the submittal requirements of a fire alarm system.