



Fire Safety Consultants, Inc.
Specializing in Fire, Building, and Life Safety
www.firesafetyfsci.com

Corporate Office
2175 Point Blvd.
Suite 380
Elgin, IL 60123
P: 847.697.1300

Regional Office
24445 Northwestern Hwy
Suite 110
Southfield, MI 48075
P: 248.545.3330

FIRE ALARM SYSTEM SUBMITTALS

Information Required for Submittal to be Reviewed by FSCI

See NFPA 72 for a complete submittal list.

- ☐ Plans must be to a reviewable scale and include a **scope of work** outlining details of the project.
- ☐ Plans must show job name and complete address.
- ☐ The square foot area of the building must be noted on the plans.
- ☐ A summary sheet or symbol list showing a device count shall be provided.
- ☐ Catalog cut sheets must be provided and **highlighted** for all components to be installed.
- ☐ Specific details must be provided regarding the offsite monitoring of the system including type of transmission means and name and location of receiving station.
- ☐ All wiring information must be shown on the plans including size, type, and all point-to-point wire runs.
- ☐ Complete battery back up calculations must be provided that clearly note **battery size to be provided**.
- ☐ Voltage drop calculations using the "UL MAX" values for notification appliances must be provided.
- ☐ All plans must have the contractor's name, address, and phone number.